



Notes

1. Allow for movement in the termination bar by using slotted anchor holes.
2. The termination bar should be 1" wide minimum and 1/8" thick.
3. The modifiedPLUS membranes may be thermofused, self-adhered, applied in hot asphalt, or applied in cold adhesive. Consult Technical Data Sheets for specific information as well as priming requirements.

modifiedPLUS Roofing Systems

TERMINATION BAR

CONVENTIONAL ROOFING ASSEMBLY

Scale: N.T.S.

Plot: 1:5

Issued: 05-14-97

Revision: 04

MB-4E97



Henry Company
 2911 Slauson Avenue, Huntington Park CA 90255
 (800) 486-1278 techservices@henry.com
<http://www.henry.com>